



Questions and Answers

For OG&E's 2024 All Source RFP

Question #1

Will OG&E consider solar assets in the 9.5-9.9MW capacity range as meeting minimum nameplate capacity per Section 1, Table 1?

A: No. The minimum nameplate Capacity of any Project, including solar, is 10 MW as noted in Section 1, Table 1 of the 2024 All Source RFP Document.